

# A general spatio-temporal model of energy systems, STeMES, and its application to integrated wind-hydrogen-electricity networks in Great Britain

Sheila Samsatli, Nouri Samsatli and Nilay Shah

wholeSEM Conference 2015

Cambridge

6 – 7 July 2015



# Outline


---

1. Introduction
2. Integrated wind-electricity-hydrogen networks model
3. Case studies
4. Conclusions



# Meeting domestic transport demand using only on-shore wind

Wind speed m/s


- 5.00 - 6.17
- 6.17 - 6.72
- 6.72 - 7.89
- 7.89 - 10.40
- 10.40 - 15.80



Wind availability



How many wind turbines and where?  
Electricity or hydrogen?  
What will the network look like?  
Storage? What and where?  
Technologies (fuel cells, electrolysers)?



Demand


# Integrated wind-hydrogen-electricity networks model

- Modelled in STeMES\*, a general model of energy systems
- Mixed Integer Linear Programming (MILP) model
  - Determines the design and operation of the network
- Spatio-temporal model
  - Spatially-distributed (demands, wind availability, location of technologies)
  - Dynamic (demands, wind availability, storage, operation of the network depends on time)
- Network of conversion, storage and transport technologies
- Implemented in AIMMS and solved with CPLEX solver

\*S. Samsatli and N. Samsatli (2015). A general spatio-temporal model of energy systems with a detailed account of transport and storage. Computers and Chemical Engineering 80, 155-176, 0098-1354.

# Temporal representation

- Long-term strategic decisions
- Short-term operational issues (intermittency, dynamics of energy storage)




Without storage – very easy!

With storage – extra variables for initial inventories; extra constraints to link inventories within and between time levels


# Spatial representation

- GB divided into 16 transmission zones based on the National Grid SYS 17 study zones
- Each zone may contain a number of technologies for generation, conversion, storage and transport
- Transmission lines (e.g. hydrogen pipelines or electricity cables) may connect each zone to its neighbours




# Spatio-temporal wind availability

Time-series wind data for each zone were obtained from **Virtual Wind Farm Model** of Iain Staffell



Temporal distribution of wind speed in zone 13 (similar graphs were derived for the other zones)


# Spatio-temporal demand data



Department of  
Transport  
statistics for  
vehicular usage at  
different times

+

=



Hydrogen  
demand at 1km

Temporal distribution of  
hydrogen demands in Z13  
(similar graphs were derived  
for the other zones)




# Wind turbine siting constraints

## Criteria used to determine the total land area in each zone suitable for siting wind turbines


1. Annual wind speed of at least 5m/s at 45m above ground level
2. Slope of less than 15%
3. Access: a minimum distance of 500m from minor road network
4. Connectivity to National Grid: at least 200m but not more than 1500m from major road network
5. Not in SSSI (Sites of Special Scientific Interest)
6. Population impacts: at least 500m from DLUA (developed land used area)
7. Water pollution: at least 200m from river
8. Wildlife and interference: at least 250m from woodland
9. Safety: at least 5km from airports
10. Not occupied by existing wind turbines including spacing between turbines of 5 rotor diameters

# Land footprint constraint

- Total available area for wind turbines
  - Intersection of the 10 constraints
- Total available area in each zone defines the land footprint constraints in the model



# Resource-Technology Network




Network of conversion, storage and transmission technologies connecting 2 zones

# Production technology

## Wind turbines

- Considered standard on-shore wind turbines at commercial scale (i.e. rotor diameter of 100m)
- Assumed a minimum spacing of 5 rotor diameters between turbines
- Existing wind turbines can be used if it's cost-effective to do so



# Conversion technologies

---

## **Electrolysers**

- Max production rate of 69.38MW
- High pressure electrolysis at 20MPa

## **Fuel cells**

- 41.63MW solid oxide fuel cell

## **Compressors**

- Reciprocating compressors at different sizes

## **Expanders**

- Reciprocating expanders at different sizes

# Storage technologies

Characterised by their:

- Maximum available capacity
- Injectability – maximum rate that H<sub>2</sub> gas can be injected into storage
- Deliverability – maximum rate that H<sub>2</sub> gas can be withdrawn from storage

Cushion gas - the volume of gas required to be kept in a facility in order to maintain operating pressure and cannot be recovered until the facility stops operation

## Overground storage

- Compressed gas storage tanks at 20MPa
- Considered 3 sizes
  - Small - Max capacity: 0.36GWh; Injectability/deliverability: 15.13MW
  - Medium - Max capacity: 3.63GWh; Injectability/deliverability: 151.25MW
  - Large - Max capacity: 36.3GWh; Injectability/deliverability: 1512.50MW

# Underground storage

- Salt caverns, depleted oil/gas fields and aquifers
- Four underground storage considered in the model:
  - Aldborough (Z7)**
    - Salt cavern
    - Max capacity: 3.3TWh; Injectability: 9.17GW; Deliverability: 10.82GW
  - Humbly Grove (Z15)**
    - Depleted oil/gas field
    - Max capacity: 3.05TWh; Injectability: 3.79GW; Deliverability: 3.29GW
  - Rough (Z7)**
    - Depleted oil/gas field
    - Max capacity: 34TWh; Injectability: 10GW; Deliverability: 18.96GW
  - Warmingham (Z8)**
    - Salt cavern
    - Max capacity: 1.08TWh; Injectability: 4.88GW; Deliverability: 1.21GW

# Transmission technologies

## Hydrogen pipeline

- Data obtained from simulation using the pipeline model in gCCS
- Diameter: 100cm, max inlet pressure of 7.1MPa

## Electricity cables

- HVAC OHL, single circuit, 400kV, 1500MVA
- HVAC OHL, double circuit, 400kV, 2x1500MVA
- HVAC underground XLPE cable, single circuit, 400kV, 1000MVA
- HVAC underground XLPE cable, double circuit, 400kV, 2x1000MVA
- HVDC OHL, bipolar,  $\pm 400\text{kV}$ , 1500MW
- HVDC underground cable pair,  $\pm 350\text{kV}$ , 1100MW




# Centres of demand

- Transmission assumed to be between the centres of demand of each zone
- Obtained from the demand density at 1km,  $D(x, y)$

$$x_z = \frac{\iint_{S_z} xD(x, y) dx dy}{\iint_{S_z} D(x, y) dx dy}$$



$$y_z = \frac{\iint_{S_z} yD(x, y) dx dy}{\iint_{S_z} D(x, y) dx dy}$$



# Length of the distribution network

- Previous methods used a grid of square cells and assumed that demands are uniformly distributed.
- A better approximation uses the demand density,  $D(x, y)$ :


$$L_z^{network} = \iint_{S_z} \frac{D(x, y)}{C} \sqrt{(x - x_z)^2 + (y - y_z)^2} dx dy$$



# Number of fuelling stations

- Number of fuelling stations:

$$N_z^{stations} = \left[ \frac{1}{C} \iint_{S_z} D(x, y) dx dy \right]$$



Total distribution cost  $\approx$  £bn17/yr

Assuming:

- Fuelling station capacity of 1,500kg/day
- Distribution pipeline diameter of 20cm
- Capital charge factor of 3

# Production/conversion-storage-transmission network problem

## Given:

- The hydrogen demand and availability of wind power
- Characteristics of each technology (e.g. unit costs: CAPEX, O&M; efficiency)

## Determine:

- The optimal number, size and location of wind turbines, electrolysers, fuel cells, compressors, expanders and hydrogen storage
- Whether to transmit the energy as electricity or hydrogen or both
- The structure of the transmission network
- The hourly operation of each network component

## Subject to:

- Max available land area for the technologies (only land footprints of wind turbines are considered in this study)
- Satisfying all of the demands


## Objective:

- Minimise total system cost

# Base case: choose the best from all of the possible technologies


(existing wind turbines not included)

## Breakdown of costs [£M/yr] (excluding distribution costs)




- ◆ Compressed gas storage (36.30GWh<sub>hy</sub>)
- ◆ Compressed gas storage (3.63GWh<sub>hy</sub>)
- ◆ Compressed gas storage (0.36GWh<sub>hy</sub>)
- ▶ Compressor (63.76MW<sub>el</sub>)
- ▶ Expander (13.17MW<sub>el</sub>)
- ▶ Expander (1.32MW<sub>el</sub>)
- ▶ Expander (0.13MW<sub>el</sub>)
- ▶ Expander (28.67MW<sub>el</sub>)
- Electrolyser (69.38MW<sub>el</sub>)
- New wind turbine (1.23MW<sub>el</sub> at 9m/s)
- ◆ Underground storage - Humby Grove (3.05TWh<sub>hy</sub>)
- Hydrogen pipeline (9.81GW<sub>hy</sub> max flow)

## Least-cost network configuration



# Base case (cont...)


Snapshot of the operation of the transmission network (pipeline) during weekdays in summer



View in slide show mode for the animation

## Base case (cont...)


Inventory of hydrogen in the Humbly Grove underground storage (Z15)




The underground storage is being used effectively as a seasonal storage.

# Base case (cont...)


Inventory of hydrogen in overground storage (tanks) at different zones



36.3GWh storage in zone 16



3.63GWh storage in zone 4




363MWh storage in zone 8

The tank storage are being used as seasonal storage as well as for hourly balancing



# Case 2: The value of existing wind turbines


## Breakdown of costs [£M/yr] (excluding distribution costs)



## Comparison with base case


	% difference
Wind turbines	-22%
Conversion	-1%
Storage	20%
Transmission	0%
<b>Overall network</b>	<b>-7%</b>

- ◆ Compressed gas storage (36.30GWh<sub>ny</sub>)
- ◆ Compressed gas storage (3.63GWh<sub>ny</sub>)
- ◆ Compressed gas storage (0.36GWh<sub>ny</sub>)
- ▶ Compressor (63.76MW<sub>el</sub>)
- ▶ Expander (13.17MW<sub>el</sub>)
- ▶ Expander (1.32MW<sub>el</sub>)
- ▶ Expander (0.13MW<sub>el</sub>)
- ▶ Expander (28.67MW<sub>el</sub>)
- Electrolyser (69.38MW<sub>ny</sub>)
- Existing wind turbine
- New wind turbine (1.23MW<sub>el</sub> at 9m/s)
- ◆ Underground storage - Humby Grove (3.05TWh<sub>ny</sub>)
- Hydrogen pipeline (9.81GW<sub>ny</sub> max flow)



# Case 3: The value of underground storage


## Breakdown of costs [£M/yr] (excluding distribution costs)



## Comparison with base case


	% difference
Wind turbines	29%
Conversion	23%
Storage	32%
Transmission	20%
<b>Overall network</b>	<b>25%</b>

- ◆ Compressed gas storage (36.30GWh<sub>hy</sub>)
- ◆ Compressed gas storage (3.63GWh<sub>hy</sub>)
- ◆ Compressed gas storage (0.36GWh<sub>hy</sub>)
- ▶ Compressor (25.44MW<sub>el</sub>)
- ◀ Expander (13.17MW<sub>el</sub>)
- ◀ Expander (1.32MW<sub>el</sub>)
- ▶ Expander (0.13MW<sub>el</sub>)
- Electrolyser (69.38MW<sub>hy</sub>)
- New wind turbine (1.23MW<sub>el</sub> at 9m/s)
- Hydrogen pipeline (9.81GW<sub>hy</sub> max flow)



# Case 4: The value of pipeline transmission


## Breakdown of costs [£M/yr] (excluding distribution costs)



## Comparison with base case


	% difference
Wind turbines	7%
Conversion	17%
Storage	57%
Transmission	-31%
<b>Overall network</b>	<b>11%</b>

- Compressed gas storage (36.30GWh<sub>hy</sub>)
- Compressed gas storage (3.63GWh<sub>hy</sub>)
- Compressed gas storage (0.36GWh<sub>hy</sub>)
- Expander (13.17MW<sub>el</sub>)
- Expander (1.32MW<sub>el</sub>)
- Expander (0.13MW<sub>el</sub>)
- Expander (28.67MW<sub>el</sub>)
- Electrolyser (69.38MW<sub>hy</sub>)
- Fuel cell (41.63MW<sub>el</sub>)
- New wind turbine (1.23MW<sub>el</sub> at 9m/s)
- Underground storage - Humbly Grove (3.05TWh<sub>hy</sub>)
- HVAC OHL single circuit (400kV 1500MVA)
- HVAC OHL double circuit (400kV 2x1500MVA)



# Case 5: The cost of underground electricity cables


## Breakdown of costs [£M/yr] (excluding distribution costs)



## Comparison with base case

	% difference
Wind turbines	36%
Conversion	38%
Storage	83%
Transmission	8%
<b>Overall network</b>	<b>37%</b>

- Compressed gas storage (36.30GWh<sub>ny</sub>)
- Compressed gas storage (3.63GWh<sub>ny</sub>)
- Compressed gas storage (0.36GWh<sub>ny</sub>)
- Expander (13.17MW<sub>el</sub>)
- Expander (1.32MW<sub>el</sub>)
- Expander (0.13MW<sub>el</sub>)
- Expander (28.67MW<sub>el</sub>)
- Electrolyser (69.38MW<sub>ny</sub>)
- Fuel cell (41.63MW<sub>el</sub>)
- New wind turbine (1.23MW<sub>el</sub> at 9m/s)
- Underground storage - Humby Grove (3.05TWh<sub>ny</sub>)
- HVAC underground XLPE cable, single circuit (400kV 1000MVA)
- HVAC underground XLPE cable, double circuit (400kV 2x1000MVA)



## Conclusions



- All of the domestic transport demand can be met by wind
- Optimal solution (without using existing turbines)
  - Build a hydrogen pipeline network in the south of England and South Wales
  - Use the Humbly Grove underground storage
  - No wind turbines or technologies in the Midlands and Greater London
  - Northern Wales, England and Scotland self sufficient
  - Humbly Grove is used for seasonal storage
  - Storage tanks elsewhere used for hourly balancing as well as seasonal storage
- Results may change with the inclusion of more technologies, e.g. batteries, electric vehicles

## Future work

---

- Electric vehicles
  - Determine optimal penetration of electric and FC vehicles
  - Allow electricity storage in some electric vehicles
- Pipeline storage
- Integrate natural gas networks
  - H<sub>2</sub> injection into gas pipelines
- Include demands from other sectors
- Uncertainty

# The value of electric cars



## Comparison with base case

	% diff
Wind turbines	1%
Conversion	-38%
Storage	54%
Transmission	5%
<b>Overall network</b>	<b>-13%</b>

# Acknowledgements

---

- Iain Staffell for the wind data
- EPSRC funding through the wholeSEM consortium (EP/K039326/1)